

GREEN CIRCLE, INC.

Integrated HSEQR Consulting Engineers, Scientists & Trainers
(Recognised By Ministry of Environment and Forests, New Delhi Under EPA 1986)
(No. Q - 1508 / 32 / 2007 - CPW)

(ISO 9001:2008, 14001:2004, OHSAS 18001:2007 & NABL/ISO/IEC 17025 : 2005 Certified Organisation)

Report No: GCI/V/LAB/EM-G0128/16-MV/16-17/May-00/0152

Date: 10/05/2017

ANALYSIS REPORT (For the Month of May-2017)

Client Details		Sample Details	
Name	M/s. Clear Ford India Pvt Ltd.	Sample Code	GCI/V/17/E11/WW1-WW2
Address	Jambudiyapura, Baroda – Halol Highway, Golder Chokdi Vadodara	Location	STP Inlet & STP Outlet
		Quantity	1000 ml
Sampling Done By	Mr. Nikesh	Date of Sampling	05/05/2017
Analysis Started Date	05/05/2017	Sampling Method	APHA 1060
Analysis Completion Date	10/05/2017	Sample Received Date	05/05/2017

WASTE WATER ANALYSIS RESULTS

Sr. No.	Parameters	Unit	STP Inlet	STP Outlet	Reference Method
1.	Nitrate	mg/L	4.29	19.78	APHA4500 NO ₃ - B
2.	Total Suspended Solids	mg/L	12	2	APHA 2540 D
3.	Biochemical Oxygen Demand (3 days at 27°C)	mg/L	56	8	APHA 5210
4.	Chemical Oxygen Demand	mg/L	240	40	APHA 5220
5.	Total Coliform	MPN/100 ml	>1600	920	APHA 9221-B
6.	Faecal Coliform	MPN/100 ml	540	220	APHA 9221-E



Authorized Signatory

- Analysis is subject to the condition In Which the Sample Is received at our Laboratory.
- Reports cannot be used as an evidence anywhere including judiciary purpose without our prior permission.
- Sample will be retained till one month from the date of sampling.

CORP. OFFICE & R & D MUMBAI : Green Empire (Anupushpam), Above Axis Bank, Nr. Yash Complex, Gotri Road, Vadodara - 390 021 (Gujarat), India.
Tel. : 0265-2371269, Cell : 093285 83835 E-mail : info@greencircleinc.com, Website : www.greencircleinc.com
: 6, Ground Floor, Shakuntala Niwas, M.G. Road, Opp. G.H. School, Borivali (E) Mumbai - 400 066 India.
Cell : 099875 49920 Tel. : 022-28943090/60

: ALSO AT :

NEW DELHI GOA PUNE BENGALURU RUDRAPUR HYDERABAD KOLKATA

: OVERSEAS :

AUSTRALIA OMAN KUWAIT AFRICA VIETNAM UAE